

# Plant Emergency Generator



- Leakage observed from Radiator on July 26
- Rental Generator received on July 28
- Hook up of Rental Generator on July 30
- Completed Radiator Repair on August 9<sup>th</sup>
- Working on Annual maintenance and other related generator issues
- Estimate for repair and rentals - \$70,000
- Will bring it back to Board on Aug 27<sup>th</sup> with final costs.



# 10 inch Fire Line



- Leak is in backyard at 484 Pilarcitos
- In the same area between two houses is 10 inch and two inch water, 1.5 inch gas and phone lines
- Currently we are not certain of the exact location of the line
- Currently SAM staff are on 24 hr fire watch
- Distance between 484 and 456 Pilacritos is @10 ft
- Contractor will be on T&M starting tomorrow
- Will bring back to Board on Aug 27<sup>th</sup> with more details.

