


Wastewater Resilience Planning

Timothy Monahan, P.E.
Kishen Prathivadi, P.E., PMP

March 2018

Pipeline Technology Conference / Pipe and Sewer Conference
Berlin, Germany

Presentation Outline





1

Introduction

Wastewater
Resilience
Planning

Introduction



Presenters

- Timothy Monahan, P.E.
Project Manager
SRT Consultants, Inc. San Francisco, CA
- Kishen Prathivadi, P.E., PMP
Engineering and Construction Contracts Manager
Sewer Authority Mid-Coastside, Half Moon Bay, CA

Introduction



The Sewer Authority Mid-Coastside (SAM) is a coalition of three entities on California's Pacific coast 30 miles (48 km) south of San Francisco

- City of Half Moon Bay
- Granada Community Services District
- Montara Water and Sanitary District



Granada Community Services District



Montara Water and Sanitary District

Introduction



SAM provides wastewater treatment services and contract wastewater collection services for approximately 30,000 people in these 6 communities:

- City of Half Moon Bay
- El Granada
- Miramar
- Montara
- Moss Beach
- Princeton by the Sea



Introduction



SAM's assets:

- 3 regional wastewater pumping stations
- 6.5 miles (10.5 km) of force mains and interceptors
- 1 regional wastewater treatment plant
- 1 ocean outfall



Introduction



- Water agencies in the United States are required to prepare vulnerability assessment per the Environmental Protection Agency
- Although not required, wastewater agencies prepare similar assessments to reduce risk of service failures
- Resilience planning is the product of these assessments

Introduction




- Resilience in ecology:

Capacity of an ecosystem to survive, adapt, and grow in the face of unforeseen changes

- Resilience in engineered systems:


Capacity of the system to absorb disturbance while undergoing change so as to retain the same function, structure, identity, and response mechanisms



Stressors to SAM's WWTP Assets



- Malevolent: sabotage of physical and cyber assets
- Natural: flooding, wild fires, earthquake
- Electro-mechanical failure
 - General failure
 - Lack of spare parts
 - Age



Assessment Methodology



- Performance Goals of SAM's WWTP:
 - Average dry weather flow 4 MGD (18,200 m³/day)
 - Peak wet weather capacity – 15 MGD (68,200 m³/day)
- Challenges to Meeting Performance Goals
 - Lack of emergency storage
 - Lack of redundancy
 - Aging infrastructure

Evaluation of SAM's Assets



- Assets were evaluated based on their criticality to the overall performance of the WWTP and pump stations
- Evaluation identified assets that if fail could result in:
 - *Prolonged or widespread interruption of service*
 - *Degradation of other systems*
 - *Injuries/fatalities*
 - *Detrimental economic impact to SAM or the community*
 - *Detrimental environmental impact*

Age of SAM's Assets



Asset Type	Useful Life (years)	Current Age (years)
Pipelines	50	32
Structures	30 to 50	16 to 32
Process Equipment	15 to 20	30
Auxiliary Equipment	10 to 15	30

Probability of Failure



Rate of occurrence:	Once in 10 years	Once in 5-10 years	Once in 3-5 years	Once in 1-3 years	Less than once/yr.
Probability of failure rating:	0.5	2.5	5.0	7.5	10.0

Consequence of Failure



Three criteria were considered:

1. *Impact on the WWTP effluent quality*
2. *Impact on the WWTP treatment capacity*
3. *Ability to return the equipment to service (including staff)*

Consequence of Failure



Criteria	Relative Weight	Anticipated Consequences		
Effluent quality	33%	none	Mid-term Non-compliance	Immediate Non-compliance
Treatment capacity	33%	none	No more redundancy or peak capacity <15 MGD	Failed process or average capacity <4 MGD
Ability to return to service	34%	Immediate repair replacement possible	Repair possible before treatment is impacted	No contingency plan preparedness uncertain
Criteria rating:		1 = negligible	5 = low	10 = severe
Consequence rating:		Sum of the three weighted criteria ratings		

Determining Risk Score




Risk Score = Probability of Failure Rating x Consequence Rating


Example:

Asset	Probability of Failure Rating	Consequence of failure			Consequence of Failure Rating	Risk Score
		Quality	Capacity	Service-ability		
		33%	33%	34%		
Belt filter press	10	5	10	10	8.4	84

$$\text{Risk Score} = 10 \times (5 \times 0.333 + 10 \times 0.333 + 10 \times 0.344) = 84$$

Risk Scores Used to Prioritize Projects






Assessment Results



- 50 major projects identified
- Projects ranked according to Risk Score from lowest to highest
- Projects further prioritized:
 - Mandatory – regulatory or safety driven
must do
 - Replacement and Rehabilitation
must be done
 - Sustainability, energy reduction, optimization
should be done

Assessment Results

- 5 year capital improvement plan
- \$22.0 million in projects
- Update each year
- Proactive funding
- Risk reduction



SAM's Wastewater Resilience Projects



Wastewater Pumping Station Rehabilitation



SAM's Wastewater Resilience Projects



Force Main Replacement



SAM's Wastewater Resilience Projects



Force Main By-Pass Improvements



SAM's Wastewater Resilience Projects



Interceptor Repairs and CIPP Lining




SAM's Wastewater Resilience Projects



Wet Weather Storage Facility





Conclusion



Wastewater resilience planning:

- *Improves safety*
- *Improves reliability*
- *Reduces risk of failure*
- *Allows systematic modernization of facilities*
- *Prioritizes competing projects*
- *Allows more predictable funding vs reactionary spending*

Q&A